

CERTIFICATE

Issued to:
Applicant:
Batt Cables PLC
The Belfry, Fraser Road, Erith
DA81QH Kent
Great Britain

Product : XLPE insulated and PVC sheathed cable 0,6/1 kV with improved fire performance and combined armour/protective earth conductor.
Trade name : BATT CABLES
Type : VG-YMvKasmb

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard DEKRA K 42C-1-4-D based on HD 604 S1:1994/A3:2005, Part 4 Section D;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2150792

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 28 April 2016 and expires upon withdrawal of one of the above mentioned standards.

DEKRA Certification B.V.

drs. G.J. Zoetbrood
Managing Director

H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	XLPE insulated and PVC sheathed cable 0,6/1 kV with improved fire performance and combined armour/protective earth conductor.
trade name	:	BATT CABLES
type	:	VG-YMvKasmb
rated voltage	:	0,6/1kV
conductor	:	circular copper (class 1 and class 2)
insulation	:	XLPE compound
inner covering	:	unvulcanized rubber or plastic compound
inner sheath	:	PVC compound of type PVC/ST
armour	:	an assembly of flat galvanized steel and plain copper wires surrounded by a counter-helix of galvanized steel tape or plain or tinned copper tape
oversheath	:	PVC compound of type PVC/ST
tested cable	:	5x35mm ²
certified cables	:	complete range according Table 5 of HD 604 S1:1994/A3:2005 Part 4 Section D

TESTS**Test requirements**

DEKRA K 42C-1-4-D based on HD 604 S1:1994/A3:2005, Part 4 Section D;

Test result

The test results are laid down in DEKRA test file

Remarks

This KEMA-KEUR certificate is based on KEMA-KEUR certificate, dated 28 April 2016.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen
Checked by : A.A. Mackenbach