

CERTIFICATE

Issued to:
Applicant:
Batt Cables PLC
The Belfry, Fraser Road, Erith
DA81QH Kent
Great Britain

Product : XLPE insulated and PVC sheathed cable with improved fire performance and combined armour/protective earth conductor
Trade name : BATT CABLES (U)
Typel : VO-YMvKasmb

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard KEMA 42C-1-4-D:1995 based on HD 604 S1:1994/A3:2005 (Part 4 Section D) and additional IEC 60332-3-22:2000/A1:2008
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2144451

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 1 April 2014 and expires upon withdrawal of one of the above mentioned standards.

DEKRA Certification B.V.

drs. G.J. Zoetbrood
Managing Director

H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	XLPE insulated and PVC sheathed cable with improved fire performance and combined armour/protective earth conductor
trade name	:	BATT CABLES (U)
type	:	VO-YMvKasmb
rated voltage	:	0,6/1kV
conductor	:	circular copper (class 1 and class 2)
insulation	:	XLPE compound
inner covering	:	unvulcanized rubber or plastic compound (if applicable).
innersheath	:	PVC compound of type PVC/ST
oversheath	:	PVC compound of type PVC/ST
tested cable for type testing	:	3x2,5mm ²
tested cable for IEC 60332-22 test	:	3x2,5mm ²
certified cables	:	1-61 conductors x 1,5-2,5mm ² . All cables as mentioned in table HD 604 S1:1994/A3:2005 Part 4 Section D.

TESTS**Test requirements**

KEMA 42C-1-4-D:1995 based on HD 604 S1:1994/A3:2005 Part 4 Section D
Additional IEC 60332-3-22:2000/A1:2008

Test result

The test results are laid down in DEKRA test file 2169817.01.

Remarks

This KEMA-KEUR certificate is corresponding with KEMA-KEUR certificate no. 2169817.01 of 4 March 2014.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen

Checked by : B. Vos