



TABLE 4E2A- Multicore 90 °C thermosetting insulated and thermoplastic sheathed cables, non-armoured (COPPER CONDUCTORS)

Ambient temperature: 30 °C Conductor operating temperature: 90 °C

CURRENT-CARRYING CAPACITY (amperes)

Conductor cross-sectional area	Reference Method A (enclosed in conduit in thermally insulating wall etc.)		Reference Method B (enclosed in conduit on a wall or in trunking etc.)		Reference Method C (clipped direct)		Reference Method E (free air or on a perforated cable tray etc, horizontal or vertical)	
	1 two-core cable*, single-phase AC or DC	1 three- or four-core cable*, three-phase AC	1 two-core cable*, single-phase AC or DC	1 three- or four-core cable*, three-phase AC	1 two-core cable*, single-phase AC or DC	1 three- or four-core cable*, three-phase AC	1 two-core cable*, single-phase AC or DC	1 three- or four-core cable*, three-phase AC
1	2	3	4	5	6	7	8	9
(mm ²)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)
1	14.5	13	17	15	19	17	21	18
1.5	18.5	16.5	22	19.5	24	22	26	23
2.5	25	22	30	26	33	30	36	32
4	33	30	40	35	45	40	49	42
6	42	38	51	44	58	52	63	54
10	57	51	69	60	80	71	86	75
16	76	68	91	80	107	96	115	100
25	99	89	119	105	138	119	149	127
35	121	109	146	128	171	147	185	158
50	145	130	175	154	209	179	225	192
70	183	164	221	194	269	229	289	246
95	220	197	265	233	328	278	352	298
120	253	227	305	268	382	322	410	346
150	290	259	334	300	441	371	473	399
185	329	295	384	340	506	424	542	456
240	386	346	459	398	599	500	641	538
300	442	396	532	455	693	576	741	621
400	-	-	625	536	803	667	865	741

* with or without a protective conductor

NOTES:

1. Where it is intended to connect the cables in this table to equipment or accessories designed to operate at a temperature lower than the maximum operating temperature of the cable, the cables should be rated at the maximum operating temperature of the equipment or accessory (see Regulation 512.1.5).
2. Where it is intended to group a cable in this table with other cables, the cable should be rated at the lowest of the maximum operating temperatures of any of the cables in the group (see Regulation 512.1.5).
3. For cables having flexible conductors see section 2.4 of this appendix for adjustment factors for current-carrying capacity and voltage drop.

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.



TABLE 4E2B

Conductor operating temperature: 90 °C

VOLTAGE DROP (per ampere per metre):

Conductor cross-sectional area	Two-core cable, DC	Two-core cable, single-phase AC			Three- or four-core cable, three-phase AC		
	2	3			4		
(mm ²)	(mV/A/m)	(mV/A/m)			(mV/A/m)		
		R	X	Z	R	X	Z
1	46	46			40		
1.5	31	31			27		
2.5	19	19			16		
4	12	12			10		
6	7.9	7.9			6.8		
10	4.7	4.7			4.0		
16	2.9	2.9			2.5		
25	1.85	1.85	0.160	1.90	0.160	0.140	1.65
35	1.35	1.35	0.151	1.35	1.15	0.135	1.15
50	0.98	0.99	0.155	1.00	0.86	0.1351	0.87
70	0.67	0.67	0.150	0.69	0.59	0.130	0.60
95	0.49	0.50	0.150	0.52	0.43	0.130	0.45
120	0.39	0.40	0.145	0.42	0.34	0.130	0.37
150	0.31	0.32	0.145	0.35	0.28	0.125	0.30
185	0.25	0.26	0.145	0.29	0.22	0.125	0.26
240	0.195	0.200	0.140	0.24	0.175	0.125	0.21
300	0.155	0.160	0.140	0.21	0.140	0.120	0.185
400	0.120	0.130	0.140	0.115	0.115	0.120	0.165

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.