



**TABLE 4E4A- Multicore armoured 90 °C thermosetting insulated cables
(COPPER CONDUCTORS)**

Air ambient temperature: 30 °C
 Ground ambient temperature: 20 °C
 Conductor operating temperature: 90 °C

CURRENT-CARRYING CAPACITY (amperes):

Conductor cross-sectional area	Reference Method C (clipped direct)		Reference Method E (in free air or on a perforated cable tray etc, horizontal or vertical)		Reference Method D (direct in ground or in ducting in ground, in or around buildings)	
	1 two-core cable, single-phase AC or DC	1 three- or 1 four-core cable, three-phase AC	1 two-core cable, single-phase AC or DC	1 three- or 1 four-core cable, three-phase AC	1 two-core cable, single-phase AC or DC	1 three- or 1 four-core cable, three-phase AC
1	2	3	4	5	6	7
mm ²	(A)	(A)	(A)	(A)	(A)	(A)
1.5	27	23	29	25	25	21
2.5	36	31	39	33	33	28
4	49	42	52	44	43	36
6	62	53	66	56	53	44
10	85	73	90	78	71	58
16	110	94	115	99	91	75
25	146	124	152	131	116	96
35	180	154	188	162	139	115
50	219	187	228	197	164	135
70	279	238	291	251	203	167
95	338	289	354	304	239	197
120	392	335	410	353	271	223
150	451	386	472	406	306	251
185	515	441	539	463	343	281
240	607	520	636	546	395	324
300	698	599	732	628	446	365
400	787	673	847	728		

NOTES:

1. Where it is intended to connect the cables in this table to equipment or accessories designed to operate at a temperature lower than the maximum operating temperature of the cable, the cables should be rated at the maximum operating temperature of the equipment or accessory (see Regulation 512.1.5).
2. Where it is intended to group a cable in this table with other cables, the cable should be rated at the lowest of the maximum operating temperatures of any of the cables in the group (see Regulation 512.1.5).

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.



TABLE 4E4B

Conductor operating temperature: 90 °C
 VOLTAGE DROP (per ampere per metre):

Conductor cross-sectional area		Two-core cable, DC		Two-core cable, single-phase AC		Three- or four-core cable, three-phase AC	
		2		3		4	
(mm ²)		(mV/Nm)		(mV/Nm)		(mV/Nm)	
1.5		31		31		27	
2.5		19		19		16	
4		12		12		10	
6		7.9		7.9		6.8	
10		4.7		4.7		4.0	
16		2.9		2.9		2.5	
		R	X	Z	R	X	Z
25	1.85	1.85	0.160	1.90	1.60	0.140	1.65
35	1.35	1.35	0.155	1.35	1.15	0.135	1.15
50	0.98	0.99	0.155	1.00	0.86	0.135	0.87
70	0.67	0.67	0.150	0.69	0.59	0.130	0.60
95	0.49	0.50	0.150	0.52	0.43	0.130	0.45
120	0.39	0.40	0.145	0.42	0.34	0.130	0.37
150	0.31	0.32	0.145	0.35	0.28	0.125	0.30
185	0.25	0.26	0.145	0.29	0.22	0.125	0.26
240	0.195	0.20	0.140	0.24	0.175	0.125	0.21
300	0.155	0.16	0.140	0.21	0.140	0.120	0.185
400	0.120	0.13	0.140	0.190	0.115	0.120	0.165

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.