



TABLE 4F1A- 60 °c thermosetting insulated flexible cables with sheath, non-armoured (COPPER CONDUCTORS)

Ambient temperature: 30 °C

Conductor operating temperature: 60 °C

CURRENT-CARRYING CAPACITY (amperes):

Conductor cross-sectional area	Single-phase AC or DC	Three-phase AC	Single-phase AC or DC
	1 two-core cable, with or without protective conductor	1 three-core, four-core or five-core cable	2 single-core cables, touching
1	2	3	4
(mm ²)	(A)	(A)	(A)
4	30	26	-
6	39	34	-
10	51	47	-
16	73	63	-
25	97	83	-
35	-	102	140
50	-	124	175
70	-	158	216
95	-	192	258
120	-	222	302
150	-	255	347
185	-	291	394
240	-	343	471
300	-	394	541
400	-	-	644
500	-	-	738
630	-	-	861

NOTES:

1. The current ratings tabulated are for cables in free air but may also be used for cables resting on a surface. If the cable is to be wound on a drum on load the ratings should be reduced in accordance with NOTE 2 below and for cables which may be covered, NOTE 3 below.

2. Flexible cables wound on reeling drums

The current ratings of cables used on reeling drums are to be reduced by the following factors:

Radial type drum: ventilated:85 % unventilated, 75%

Ventilated cylindrical type drum: 1 layer of cable: 85 %, 2 layers of cable:65 %, 3 layers of cable: 45 %, 4 layers of cable:35 %

A radial type drum is one where spiral layers of cable are accommodated between closely spaced flanges; if fitted with solid flanges the ratings given above should be reduced and the drum is described as non-ventilated. If the flanges have suitable apertures the drum is described as ventilated.

A ventilated cylindrical cable drum is one where layers of cable are accommodated between widely spaced flanges and the drum and end flanges have suitable ventilating apertures.

Where cable may be covered over or coiled up whilst on load, or the air movement over the cable restricted, the current rating should be reduced. It is not possible to specify the amount of reduction but the table of rating factors for reeling drums can be used as a guide.

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.



TABLE 4F1B

Conductor operating temperature: 60 °C

VOLTAGE DROP (per ampere per metre):

Conductor cross-sectional area	Two-core cable, DC	Two-core cable, single-phase AC			1 three-core, four-core or five-core cable, three-phase AC			2 single-core cables, touching				
								DC		Single-phase AC*		
1	2	3			4			5	6			
mm ²	mV/Nm	mV/Nm			mV/Nm			mV/Nm	mV/A/m			
4	12	12			10			-	-			
6	7.8	7.8			6.7			-	-			
10	4.6	4.6			4.0			-	-			
16	2.9	2.9			2.5			-	-			
		R	X	Z	R	X	Z		R	X	Z	
25	1.80	1.80	0.175	0.185	1.55	0.150	1.55	-				
35	-	-	-	-	1.10	0.150	1.15	1.31	1.31	0.21	1.32	
50	-	-	-	-	0.83	0.145	0.84	0.91	0.91	0.21	0.93	
70	-	-	-	-	0.57	0.140	0.58	0.64	0.64	0.20	0.67	
95	-	-	-	-	0.42	0.135	0.44	0.49	0.49	0.195	0.53	
120	-	-	-	-	0.33	0.135	0.36	0.38	0.38	0.190	0.43	
150	-	-	-	-	0.27	0.130	0.30	0.31	0.31	0.190	0.36	
185	-	-	-	-	0.22	0.130	0.26	0.25	0.25	0.190	0.32	
240	-	-	-	-	0.170	0.130	0.21	0.190	0.195	0.185	0.27	
300	-	-	-	-	0.135	0.125	0.185	0.150	0.155	0.180	0.24	
400	-	-	-	-	-	-	-	0.115	0.120	0.175	0.21	
500	-	-	-	-	-	-	-	0.090	0.099	0.170	0.20	
630	-	-	-	-	-	-	-	0.068	0.079	0.170	0.185	

NOTE: * A larger voltage drop will result if the cables are spaced.

Whilst BATT CABLES plc endeavours to ensure the information on the website, specification sheets and all other technical information is accurate, the information is for guidance only and it is subject to change without notice or liability. Batt Cables Plc is not responsible for the consequences of any inadequacies, inaccuracies or other deficiencies contained therein. When selecting cable accessories, please note that the actual cable dimensions may vary due to manufacturing tolerances.

All tables are reproduced by kind permission of The Institute of Engineering & Technology from IEEE Regs, 18th Edition. However, it should be noted that in order to apply these tables correctly, reference is required to appendix 4 of the 18th edition of the wiring regulations, which may be obtained from Institution of Engineering & Technology.